

James Madison University
 Facilities Management
 MONTHLY INSPECTION AND MAINTENANCE CHECKLIST
 FOR SELF-CONTAINED BREATHING APPARATUS

INSPECTION COMPLETED BY: _____ DATE: _____

NUMBER	GUAGE READING	CYLINDER CHANGED (PSI)	REGULATOR OK	FACEPIECE & LOW PRESSURE HOSE OK	CLEANED AND SANITIZED	HYDROSTATIC TEST DATE	HARNESS OK	STRAPS EXTENDED	ENTIRE APPARATUS OK	COMMENTS

- NOTES:
- 1) All SCBAs and extra tanks must be inspected at least monthly and whenever they are used.
 - 2) After use, each SCBA must be thoroughly cleaned and sanitized.
 - 3) Cylinders must be changed if they are below 1800 lbs. Psi. the local fire department will refill bottles. If you have bottles that need to be filled, contact your supervisor.